



# BULGARKONTROLA

**BULGARKONTROLA SA -Sofia**

*Conformity Assessment Body for Construction Products*

*With identification number 14 and Permit № ПОССП-14 on 15.09.2016*

*Issued by Ministry of Regional Development and Public Works*

## CERTIFICATE OF CONFORMITY

**14 – НУРВСИРСБ – 4043**

Issued pursuant to Art. 14, par. 1 and par. 2 of the Regulation № ПД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

### **VALVES FOR WATER SUPPLY “Bermad”**

Made of ductile cast iron and epoxy coating,  
with product range, operating pressure, dimensions and evaluated characteristics in accordance  
with national requirements as per Supplement № 1 to this Certificate.

place on the market by  
**BERMAD CS Ltd**  
**ISRAEL-22808 KIBBUTZ EVRON**

manufactured by  
**BERMAD CS Ltd**  
**ISRAEL-22808 KIBBUTZ EVRON**

This certificate certifies that the product has been evaluated and meets national requirements set out in

**BDS EN 1074-1:2004**

**BDS EN 1074-4:2004**


**BDS EN 1074-5:2004**

*and item 7.5. of Annex 3 to item 2 of the Order № 02-14-1329 from 03.12.2015  
of the Minister of Regional Development and Public Works*

The certificate was issued on **21/11/2024** cancel the **Certificate № 14-НУРВСИРСБ-3712 from 01/11/2022** and remains valid until **31/10/2025**, provided that the manufacturer ensures consistency of product characteristics and the conditions of production or production control have not been changed significantly.

**Place: Sofia**  
**Date: 21/11/2024**

**Director of "Conformity Assessment" Dept.**  
**/T. Lyubenova/**



FC/CPNR -7-3.9/02

стр. 1/2



### 1. Product range, operating pressure and dimensions

№	Product range Series	Operating pressure PN (bar)	Nominal dimension DN (mm)
<b>I. Control valves with flow rate, level and pressure control functions made of ductile cast iron with epoxy coating</b>			
1.1	Series 400	10/16	50÷400
1.2	Series 700	10/16/25	40÷500
1.3	Series 700 EN	10/16/25	40÷500
1.4	Series 700 ES	10/16/25	40÷600
1.5	Series 700 Large Diameter	10/16	600÷900
1.6	Series 800	10/16/25/40	40÷500
1.7	Series 900	10/16/	40÷-250
<b>II. Air valves made of ductile cast iron with epoxy coating and/or plastic materials</b>			
2.1	Kinetic Air Valve K10	10/16	20÷50
2.2	Automatic Air Valve A10	10	20÷25
2.3	Automatic Air Valve A30	10/16	20÷25
2.4	Combination Air Valve C10	10/16	20÷80
2.5	Combination Air Valve C30	10/16	20÷80
2.6	Combination Air Valve C30-C	10/16	50
2.7	Combination Air Valve C70	10/16/25/40	50÷-200
2.8	Combination Air Valve C75	10/16/25/40	80÷300

### 2. Evaluated characteristics in accordance with national requirements

Characteristics	Requirement to declare / border level
Resistance to internal pressure of the body and all pressurized parts	no damage and leakage at $P = (1,5 \times PN)$ bar
Resistance to the closing body of internal pressure	no damage and leakage at $P = (1,5 \times PN)$ bar
Tightness of the body in internal pressure and any parts under Pressure	no damage and leakage at $P = (1,5 \times PN)$ bar
Tightness of the body at a certain pressure	without exceeding the leaks according to levels of A-F, at $P = (1,1 \times PN)$ bar
Tightness of the body at a certain low pressure	without exceeding the leaks according to levels of A-F, at $P = 0,5$ bar

Place: Sofia  
Date: 21/11/2024

Director of "Conformity Assessment" Dept. *T. Lyubanova*  
**T. Lyubanova**

